

# Environ Tech Laboratories

NABL Accredited (ISO/IEC 17025:2017)/ MoEF & CC Recognized  
PPCB Approved/ OHSAS 45001:2018

Plot No.62, Janta Industrial Estate,  
Airport Road, Sector 82, S.A.S. Nagar  
(Mohali)-160062 Punjab  
Mob. 9417210081, 9417220081  
9464000081, Tel. 9463000081

GSTIN : 03BPEPS9693P1ZV  
PAN No. BPEPS9693P

DISPATCH No:-ETL/DSP/

Date:- 21-10-2020  
Page 1 of 1

## TEST REPORT

To  
M/s Madhav KRG Limited.,  
Village- Akalgarh, Mandi, Gobindgarh (Pb).

|                               |                      |                        |                        |
|-------------------------------|----------------------|------------------------|------------------------|
| Report No.                    | ETL/44/2020/G/201591 | Report Date            | 21.10.2020             |
| Your Ref. No.                 | Nil                  | Type of sample         | STP Inlet              |
| Sample Code given by customer | Nil                  | Quantity               | 2 LITER                |
|                               |                      | Date of sampling       | 16.10.2020             |
| Sampling Location             | Within Premises      | Date of sample receipt | 17.10.2020             |
| Sample Collected By           | Lab Person           | Sample I.D.            | ETL/32/2020/G/1591     |
| Sampling procedure            | As per SOP           | Date of test           | 17.10.2020- 21.10.2020 |

| S. NO. | PARAMETERS                                      | TEST RESULTS | TEST METHODS                                                                      |
|--------|-------------------------------------------------|--------------|-----------------------------------------------------------------------------------|
| 1.     | pH                                              | 7.50         | IS: 3025 (Part – 11)2002, Reaff.2017, APHA 23 <sup>rd</sup> Edition:2017-4500B    |
| 2.     | Total Suspended Solids, mg/L                    | 160          | IS: 3025 (Part – 17)2002, Reaff.2017, APHA 23 <sup>rd</sup> Edition:2017-(2540D)  |
| 3.     | Total Dissolved Solid, mg/L                     | 744          | IS: 3025 (Part – 16)2006, Reaff.2017, APHA 23 <sup>rd</sup> Edition:2017-2540C    |
| 4.     | Bio-chemical Oxygen Demand at 27°C 3 days, mg/L | 60           | IS: 3025 (Part – 44)2009, Reaff.2014, APHA 23 <sup>rd</sup> Edition:2017-5210B    |
| 5.     | Chemical Oxygen Demand, mg/L                    | 176          | IS: 3025 (Part – 58)2006, Reaff.2017, APHA 23 <sup>rd</sup> Edition:2017-5520B    |
| 6.     | Oil and Grease, mg/L                            | 13           | IS: 3025 (Part – 39)2003, Reaff.2017, APHA 23 <sup>rd</sup> Edition:2017-5520B    |
| 7.     | Total Hardness (as CaCO <sub>3</sub> ) mg/l,    | 278          | APHA 23 <sup>rd</sup> Edition:2017 -2340 C                                        |
| 8.     | Alkalinity ( as CaCO <sub>3</sub> ) mg/l        | 475          | APHA 23 <sup>rd</sup> Edition:2017-2320 B                                         |
| 9.     | Iron ( as Fe) mg/l                              | 0.08         | APHA 23 <sup>rd</sup> Edition 2017-3500 Fe B                                      |
| 10.    | Conductivity, micro mhos/cm at 25°C             | 1654         | IS: 3025 (Part – 14)2003, Reaff.2017, APHA 23 <sup>rd</sup> Edition:2017-2520 B   |
| 11.    | Total Phosphate as PO <sub>4</sub>              | 23           | IS:3025(Part-31)2003, Reaff. 2014. APHA 23 <sup>rd</sup> Edition:2017 -4500-P C&E |
| 12.    | Chloride (as Cl), mg/l,                         | 170          | APHA 23 <sup>rd</sup> Edition:2017 -4500-Cl B                                     |
| 13.    | Turbidity, NTU max                              | 10           | APHA 23 <sup>rd</sup> Edition 2017 2130 B                                         |

Note: ND Denotes Not Detectable

1. The test report refers only to tested sample and applicable parameters.
2. This report can neither be used as evidence in the court of law nor can it be used in part or full in any media without prior permission.
3. The sample will be destroyed after thirty days from the date of issue of test report unless otherwise specified.

Checked By



\*End of Report\*

(Authorized Signatory)

AJEET SINGH  
Dy. Technical Manager  
Environ Tech Laboratories

Testing of Water, Waste Water, Soil, Food, Ambient Air, Noise Monitoring & Stack Emission

Email : envrontechlab72@yahoo.com, director@envrontechlab.in | Website : envrontechlab.com

NOT VALID FOR LEGAL PURPOSES