



Analyzing for an Assured
Future

NOIDA TESTING LABORATORIES

(A Government Approved Testing Laboratory)

(An ISO : 9001 : 2015, 14001 : 2015 & ISO 45001 : 2018 & NABL Accredited Laboratory)

MoEF & CC (Ministry of Environment, Forest & Climate Change), UPPCB & HSPCB Recognized Laboratory

Phone : +91-9313611642, 8510081921, 7503031145, 8527870572, 7503031146, 9999794369

TEST CERTIFICATE

Page 1 of 1

TEST REPORT

To
M/s Madhav KRG Limited,
(Previously Known as Madhav alloys Pvt. Ltd.)
Village- Akalgarh, Mandi, Gobindgarh (Pb).

Report No.	WW-130421-23	Report Date	20.04.2021
Your Ref. No.	Nil	Type of sample	STP Ro Reject Water
Sample Code given by customer	After RO	Quantity	2 LITER
Sampling Location	Within Premises	Date of sampling	12.04.2021
Sample Collected By	Lab Person	Sample I.D.	Nil
Sampling procedure	As per SOP	Date of test	13.04.2021 – 20.04.2021

S. NO.	PARAMETERS	TEST RESULTS	TEST METHODS
1.	pH	7.41	IS: 3025 (Part - 11)2002, Reaff.2017, APHA 23 rd Edition:2017-4500B
2.	Total Suspended Solids, mg/L	Nil	IS: 3025 (Part -17)2002, Reaff.2017, APHA 23 rd Edition:2017-(2540D)
3.	Conductivity, mhos/cm	1776	APHA 23 rd Edition:2017-2510B
4.	Bio-chemical Oxygen Demand at 27°C 3 days, mg/L	6.9	IS: 3025 (Part - 44)2009, Reaff.2014, APHA 23 rd Edition:2017-5210B
5.	Chemical Oxygen Demand, mg/L	20	IS: 3025 (Part - 58)2006, Reaff.2017, APHA 23 rd Edition:2017-5520B
6.	Phosphate as PO ₄ , mg/L	3.95	IS:3025(Part-31)2003, Reaff. 2014. APHA 23 rd Edition:2017 -4500-P C&E
7.	Residual Sodium Carbonate	0.65	Lab SOP
8.	Sodium Absorption ratio	4.5	By Calculation
9.	Ammonical Nitrogen(as N)	ND	IS: 3025(Part -34)2003 / Reaff 2014 APHA 23 rd Edition 2017 4500C
10.	Total Nitrogen	ND	IS: 3025(Part -34)2003 / Reaff 2014 APHA 23 rd Edition 2017 4500C
11.	Faecal Coliform as MPN	<01	IS 15185 2016

Note: ND Denotes Not Detectable

1. The test report refers only to tested sample and applicable parameters.
2. This report can neither be used as evidence in the court of law nor can it be used in part or full in any media without prior permission.
3. The sample will be destroyed after thirty days from the date of issue of test report unless otherwise specified.

Checked By

End of Report

(Authorized Signatory)



Laboratory : GT-20, Sector-117, Noida Gautam Budh Nagar - 201301

Branch Office : IP-2, Haridwar, Uttrakhand

Branch Office : Gayatri Nagar, Katgodam, Haldwani, Uttrakhand

E. : noida.laboratory@gmail.com, info@noidalabs.com W. : www. noidalabs.com